

Kølestykker

Anvendelse

Kølestykker anvendes i forbindelse med reguleringsventiler, termostater og ventilmotorer for beskyttelse af henholdsvis termostats/ventilmotorens pakdåse. Ved ventiltemperaturer over 170°C anvendes kølestykker af typen KS installeret med tilslutning nedad. Valg af type sker efter nedenstående retningslinier:

Type KS-4

Kølestykke, som beskytter motorens/termostats pakdåse. Anvendes ved ventiltemperaturer mellem 170°C og 250°C. For højere temperaturer se hhv. KS-5 og KS-6.

Type KS-5

Kølestykke med indbygget bælgætning, erstatter termostats pakdåse. Obligatorisk ved ventiltemperaturer mellem 250°C og 350°C.


Type KS-6

Kølestykke med indbygget bælgætning, erstatter ventilmotorens pakdåse. Obligatorisk ved ventiltemperaturer mellem 250°C og 350°C.

Håndforstillere


Håndforstilleren har en indbygget termostats pakdåse. Til tætning og manuel betjening af ventilerne, når en aktuator ikke er monteret, som f.eks. i byggeperioder (max. 170°C).

Kølestykke KS-4/
Cooling Unit KS-4




Vægt/Weight: 0,5 kg

Kølestykke KS-5/
Cooling Unit KS-5




Vægt/Weight: 0,5 kg

Kølestykke KS-6/
Cooling Unit KS-6



Vægt/Weight: 0,5 kg

Håndforstillere/
Manual Adjusting Device



Vægt/Weight: 0,6 kg

Cooling Units

Application

The cooling units are used in connection with control valves, thermostats and valve motors to protect the stuffing box. At valve temperatures above 170°C a cooling unit of type KS connected downwards should be applied of type according to the following:

Type KS-4

Cooling unit protecting the stuffing box of the motor/thermostat. To be applied at valve temperatures between 170°C and 250°C. For higher temperatures please see type KS-5 and type KS-6.

Type KS-5

Cooling unit with a built-in bellow gland, replacing the stuffing box of the thermostat. To be applied at valve temperatures between 250°C and 350°C.

Type KS-6

Cooling unit with a built-in bellow gland, replacing the stuffing box of the valve motor. To be applied at valve temperatures between 250°C and 350°C.

Manual Adjusting Device

The device has a built-in thermostat stuffing box. For sealing and manual operation of valves when an actuator has not been fitted, e.g. during periods of construction (max. 170°C).